



Colorado Department
of Public Health
and Environment

Inorganic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

IOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0134065		Laboratory ID: CO 0015	
System Name: Blue Sky Ranch		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Fred Stephenson	Phone #:	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>	Comments:	

Section III (Supplied or Completed by Public Water System)			
Sample Date: 3/22/16	Collector: Fred Stephenson	Facility ID (On Schedule): 003	Sample Pt ID (On Schedule): 003

Section IV Inorganic Chemicals (Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
3/24/16	3/28/16	160324024-02I	Antimony	7740-36-0	EPA 200.8	0.006	0.001	BDL
3/24/16	3/28/16	160324024-02I	Arsenic	7440-38-2	EPA 200.8	0.01	0.001	BDL
3/24/16	3/28/16	160324024-02I	Barium	7440-39-3	EPA 200.8	2	0.001	0.073
3/24/16	3/28/16	160324024-02I	Beryllium	7440-41-7	EPA 200.8	0.004	0.001	BDL
3/24/16	3/28/16	160324024-02I	Cadmium	7440-43-9	EPA 200.8	0.005	0.001	BDL
3/24/16	3/28/16	160324024-02I	Chromium	7440-47-3	EPA 200.8	0.1	0.001	BDL
3/24/16	3/28/16	160324024-02I	Mercury	7439-97-6	EPA 200.8	0.002	0.0001	BDL
3/24/16	3/28/16	160324024-02I	Nickel	7440-02-0	EPA 200.8	N/A	0.001	BDL
3/24/16	3/28/16	160324024-02I	Selenium	7782-49-2	EPA 200.8	0.05	0.001	BDL
3/24/16	3/31/16	160324024-02I	Sodium	7440-23-5	EPA 200.7	N/A	0.1	6.3
3/24/16	3/28/16	160324024-02I	Thallium	7440-28-0	EPA 200.8	0.002	0.001	BDL

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter
MCL: Maximum Contaminant Level

4/7/16
160324024-02I
1 / 1
M

