



Organic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

VOC/SOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0134065		Laboratory ID: CO 00063	
System Name: Blue Sky Ranch		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Fred Stephenson	Phone #: 970-247-4271	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>	Comments:	

Section III (Supplied or Completed by Public Water System)	
PWSID#: CO0134065	Sample Date: 3/22/16
Collector: Fred Stephenson	Facility ID (On Schedule): 003
Sample Pt ID (On Schedule): 003	

Section IV Volatile Organic Chemicals (Supplied or Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
3/24/16	3/31/16	160324024-01C	1,1,1-Trichloroethane	71-55-6	EPA-524.2	200	0.5	BDL
3/24/16	3/31/16	160324024-01C	1,1,2-Trichloroethane	79-00-5	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	1,1-Dichloroethylene	75-35-4	EPA-524.2	7	0.5	BDL
3/24/16	3/31/16	160324024-01C	1,2,4-Trichlorobenzene	120-82-1	EPA-524.2	70	0.5	BDL
3/24/16	3/31/16	160324024-01C	1,2-Dichloroethane	107-06-2	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	1,2-Dichloropropane	78-87-5	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	Benzene	71-43-2	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	Carbon Tetrachloride	56-23-5	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	Monochlorobenzene	108-90-7	EPA-524.2	100	0.5	BDL
3/24/16	3/31/16	160324024-01C	cis-1,2-Dichloroethylene	156-59-2	EPA-524.2	70	0.5	BDL
3/24/16	3/31/16	160324024-01C	Dichloromethane	75-09-2	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	Ethylbenzene	100-41-4	EPA-524.2	700	0.5	BDL
3/24/16	3/31/16	160324024-01C	o-Dichlorobenzene	95-50-1	EPA-524.2	600	0.5	BDL
3/24/16	3/31/16	160324024-01C	Para-Dichlorobenzene	106-46-7	EPA-524.2	75	0.5	BDL
3/24/16	3/31/16	160324024-01C	Styrene	100-42-5	EPA-524.2	100	0.5	BDL
3/24/16	3/31/16	160324024-01C	Tetrachloroethylene	127-18-4	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	Toluene	108-88-3	EPA-524.2	1000	0.5	BDL
3/24/16	3/31/16	160324024-01C	trans-1,2-Dichloroethylene	156-60-5	EPA-524.2	100	0.5	BDL
3/24/16	3/31/16	160324024-01C	Trichloroethylene	79-01-6	EPA-524.2	5	0.5	BDL
3/24/16	3/31/16	160324024-01C	Vinyl chloride	75-01-4	EPA-524.2	2	0.5	BDL
3/24/16	3/31/16	160324024-01C	Xylenes (total)	1330-20-7	EPA-524.2	10000	0.5	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

160324024-01 M

1/3
4/7/16



Organic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
4300 Cherry Creek Drive South, Denver, CO 80246-1530
Fax: (303) 758-1398; cdphe.drinkingwater@state.co.us

Revised 6/13/2014

VOC/SOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0134065		Laboratory ID: CO 00063	
System Name: Blue Sky Ranch		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Fred Stephenson	Phone #: 970-247-4271	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? <input checked="" type="checkbox"/>	Comments:	

Section V (Supplied or Completed by Public Water System)	
PWSID#: CO0134065	Sample Date: 3/22/16
Collector: Fred Stephenson	Facility ID (On Schedule): 003
Sample Pt ID (On Schedule): 003	

Section VI Synthetic Organic Chemicals (Supplied or Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
3/24/16	3/31/16	160324024-02	Dibromochloropropane	96-12-8	EPA 504.1	0.2	0.02	BDL
3/24/16	4/5/16	160324024-02B	2,4,-D	94-75-7	EPA 515.4	70	0.1	BDL
3/24/16	4/5/16	160324024-02B	2,4,5-TP	93-72-1	EPA 515.4	50	0.2	BDL
3/24/16	3/31/16	160324024-02D	Alachlor	15972-60-8	EPA 525.2	2	0.2	BDL
3/24/16	3/29/16	160324024-02E	Aldicarb	116-06-3	EPA 531.1	N/A	0.6	BDL
3/24/16	3/29/16	160324024-02E	Aldicarb sulfone	1646-88-4	EPA 531.1	N/A	1	BDL
3/24/16	3/29/16	160324024-02E	Aldicarb sulfoxide	1646-87-3	EPA 531.1	N/A	0.7	BDL
3/24/16	3/31/16	160324024-02D	Atrazine	1912-24-9	EPA 525.2	3	0.1	BDL
3/24/16	3/31/16	160324024-02D	Benzo(a)pyrene	50-32-8	EPA 525.2	0.2	0.02	BDL
3/24/16	3/29/16	160324024-02E	Carbofuran	1563-66-2	EPA 531.1	40	0.9	BDL
3/24/16	3/25/16	160324024-02A	Chlordane	57-74-9	EPA 505	2	0.2	BDL
3/24/16	4/5/16	160324024-02B	Dalapon	75-99-0	EPA 515.4	200	1	BDL
3/24/16	3/31/16	160324024-02D	Di(2-ethylhexyl)adipate	103-23-1	EPA 525.2	400	0.6	BDL
3/24/16	3/31/16	160324024-02D	Di(2-ethylhexyl)phthalate	117-81-7	EPA 525.2	6	0.6	BDL
3/24/16	4/5/16	160324024-02B	Dinoseb	85-85-7	EPA 515.4	7	0.2	BDL
3/24/16	3/25/16	160324024-02G	Diquat	85-00-7	EPA 549.2	20	0.4	BDL
3/24/16		160324024-02F	Endothall	145-73-3	EPA 548.1	100	9	BDL
3/24/16	3/25/16	160324024-02A	Endrin	72-20-8	EPA 505	2	0.01	BDL
3/24/16	3/31/16	160324024-02	Ethylene dibromide	106-93-4	EPA 504.1	0.05	0.01	BDL
3/24/16	3/25/16	160324024-02A	Heptachlor	76-44-8	EPA 505	0.4	0.04	BDL
3/24/16	3/31/16	160324024-02D		76-44-8	EPA 525.2	0.4	0.04	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

160324024-02 M

2/3
4/7/16

PWSID#: CO0134065		Section V (Supplied or Completed by Public Water System)						
Sample Date:	3/22/16	Collector:	Fred Stephenson	Facility ID (On Schedule):	003	Sample Pt ID (On Schedule):	003	
Section VI Synthetic Organic Chemicals (Supplied or Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
3/24/16	3/25/16	160324024-02A	Heptachlor epoxide	1024-57-3	EPA 505	0.2	0.02	BDL
3/24/16	3/25/16	160324024-02A	Hexachlorobenzene	118-74-1	EPA 505	1	0.1	BDL
3/24/16	3/25/16	160324024-02A	Hexachlorocyclopentadiene	77-47-4	EPA 505	50	0.1	BDL
3/24/16	3/25/16	160324024-02A	Lindane	58-89-9	EPA 505	0.2	0.02	BDL
3/24/16	3/25/16	160324024-02A	Methoxychlor	72-43-5	EPA 505	40	0.1	BDL
3/24/16	3/29/16	160324024-02E	Oxamyl	23135-22-0	EPA 531.1	200	1	BDL
3/24/16	4/5/16	160324024-02B	Pentachlorophenol	87-86-5	EPA 515.4	1	0.04	BDL
3/24/16	4/5/16	160324024-02B	Picloram	1918-02-1	EPA 515.4	500	0.1	BDL
3/24/16	3/25/16	160324024-02A	Polychlorinated biphenyl's	1336-36-3	EPA 505	0.5	0.1	BDL
3/24/16	3/31/16	160324024-02D	Simazine	122-34-9	EPA 525.2	4	0.07	BDL
3/24/16	3/25/16	160324024-02A	Toxaphene	8001-35-2	EPA 505	3	1	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

160324024-02 M

3/3
4/7/16

