



# COLORADO

Department of Public Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

October 31, 2018

ROBERT JOHNSTON  
BLUE SKY RANCH INC ASSOC OF OWNERS - PWSID CO0134065  
1 BLUE SKY DR  
DURANGO CO 81301

## Compliance Advisory - Lead and Copper Rule - Request for Information

The Colorado Department of Public Health and Environment (Department) has reviewed recently submitted lead and copper tap samples, materials evaluation and/or sampling pool information for BLUE SKY RANCH INC ASSOC OF OWNERS ("Supplier"). The Department has identified the following issues with the submitted information that the Supplier must correct:

CATEGORY	DEPARTMENT REVIEW SUMMARY	RESOLUTION ACTIVITY
<b>MATERIALS EVALUATION</b>	According to Department records, the Supplier submitted a materials evaluation form on September 15, 2016. The Supplier's material evaluation form indicated that all residences were built in 1992 or later.	No resolution required: The Department considers the materials evaluation to be complete.
<b>SAMPLE POOL</b>	According to Department records, the Supplier has submitted a lead and copper sample pool consisting of 10 Non-Tier, Representative sites. The Supplier's sample pool contains the required number of sample sites.	Based on the Supplier's materials evaluation, the sample pool is considered complete.
<b>LEAD AND COPPER TAP SAMPLING</b>	During 2018 annual lead and copper annual monitoring, the Supplier collected samples from four sites within its sample pool and one site that is currently not listed in its sample pool.	No later than annual 2019 sampling, the Supplier is required to sample high risk sites from its revised and/or verified sample pool. Failure to collect samples from high risk sites may result in future monitoring violations.

In order for the Department to continue its enhancement of the Lead and Copper Rule implementation, the Department requires the Supplier to submit the resolution activity by **January 10, 2019.**

The Supplier may submit its Lead and Copper Rule sample pool in one of two ways:

- Enter each sample pool site's information directly into the Department's data portal (encouraged) at [wqcdcompliance.com/login](http://wqcdcompliance.com/login) under "My... Sample Sites."



- Alternatively, complete and submit the Lead and Copper Sample Site Pool Location Details Form or Materials Evaluation Form. The forms are also available online at <https://www.colorado.gov/pacific/cdphe/lcr>. The form may be submitted to the Data Portal or faxed to 303-758-1398.

Additional assistance on methods to complete a materials evaluation and verification and a lead and copper sample pool can be provided by contacting Bryan Pilson by phone at 303.692.3318 or via email at [bryan.pilson@state.co.us](mailto:bryan.pilson@state.co.us). Please do not hesitate to contact him with any questions about the contents of this letter or the LCR requirements.

If there are any questions regarding the contents of this letter and/or requirements for the Supplier, please contact Margaret Talbott by phone at 303-692-3540 or by email at [margaret.talbott@state.co.us](mailto:margaret.talbott@state.co.us).

ec:

ROBERT JOHNSTON - AC

FRED STEPHENSON - OPERATOR

BRIAN DEVINE - WATER QUALITY PROGRAM MANAGER - SAN JUAN BASIN HEALTH DEPARTMENT

File: CO0134065, LA PLATA COUNTY, COMMUNITY - GROUNDWATER